ADDENDUM NO. 1

PROJECT MANUAL

UPPER OLENTANGY WATER RECLAMATION CENTER AERATION SYSTEM IMPROVEMENTS
CONTRACT 20.15
CITY OF DELAWARE, OHIO

Bids will be received until 12 P.M., local time, December 16, 2015.

This Addendum to the Project Manual is issued to modify, explain, or correct the original Project Manual and is hereby made part of the Contract Documents. Insert the number of this Addendum in the blank space provided in the Bid, page 00400-2.

A. DIVISION 0–BIDDING AND CONTRACTING REQUIREMENTS

1. SECTION 00800–SUPPLEMENTARY CONDITIONS

a. Page 00800-2

ADD the following after SC-6.06.H:

SC-6.08 Permits

Replace paragraph 6.08 with the following:

"No permits were obtained by OWNER for this Project. Ohio EPA is not requiring a Permit-to-Install for this project. CONTRACTOR shall obtain required permits. Where the requirements of any permit are more restrictive than the Drawings or the Specifications, the permit requirements shall govern. A building permit will be required from OWNER. However, OWNER will waive fees associated with the permit."

ADD the following after SC-6.21.G:

SC-8.12 Permits Obtained by OWNER

Replace paragraph 8.12 with the following:

"No permits were obtained by OWNER for this Project. Ohio EPA is not requiring a Permit-to-Install for this project. CONTRACTOR shall obtain required permits. Where the requirements of any permit are more restrictive than the Drawings or the Specifications, the permit requirements shall govern. A building permit will be required from OWNER. However, OWNER will waive fees associated with the permit."

B. SPECIFICATIONS

1. DIVISION 1–GENERAL REQUIREMENTS

a. Page 01060-1, SECTION 01060–REGULATORY REQUIREMENTS, PART 1–GENERAL, 1.04.B.

REPLACE 1.04.B. with the following:

"B. A building permit will be required from OWNER. However, OWNER will waive fees associated with the permit."

b. Page 01600-3, SECTION 01600–MATERIALS AND EQUIPMENT, PART 1–GENERAL, 1.07.

ADD the following after 1.07.C:

"D. CONTRACTOR is permitted to use OWNER's existing traveling bridge hoist/trolley located in the belt filter press room provided that CONTRACTOR demonstrates competence with the hoisting equipment through education and experience of operating personnel prior to allowed use. CONTRACTOR shall confirm the actual recommended maximum lifting capacity of the hoist/trolley and shall not exceed the recommended capacity. CONTRACTOR shall provide OWNER with written confirmation of each equipment weight proposed to be lifted by OWNER's hoist/trolley prior to its use. A representative of OWNER must be present when CONTRACTOR operates the hoisting equipment. OWNER reserves the right to disallow use of the hoisting equipment if it is observed to be improperly used at the sole discretion of OWNER. CONTRACTOR shall be responsible for any damage done to this equipment. CONTRACTOR shall provide all necessary guards, signals, safety devices, etc., required for safe hoist operation. The operation of hoisting equipment shall be in accordance with the applicable ANSI standards, the "Manual Code of Accident Prevention in Construction" of the Associated General Contractors of America, OSHA, and of other Federal, State, and municipal codes or ordinances. CONTRACTOR shall prohibit the use of material hoists for transporting personnel. Special rigging and hoisting facilities shall be provided by each trade requiring their use."

2. DIVISION 11–EQUIPMENT

a. Page 11377-1, SECTION 11377–CENTRIFUGAL BLOWER REBUILD, PART 1–GENERAL, 1.01.C.

REPLACE: 1.01.C. with the following:

"C. Allowances: CONTRACTOR shall INCLUDE in the Bid an allowance of $35,000 for the cost of Work performed by Gardner Denver, including shipping charges to and from the Authorized Gardner Denver Repair Facility. This allowance shall be adjusted by change order (up or down) based on the actual costs to CONTRACTOR."

C. DRAWINGS

1. SHEET NO. 11/ME2.1–WEST BLOWER BUILDING AND SLUDGE DISPOSAL BUILDING NO. 1 UPPER LEVEL PLAN

   ADD: Key Note 15 symbol adjacent to "LIFT WELL" in the Plan.

   ADD: Key Note 15 text as "SEE SPECIFICATION SECTION 01600 FOR DETAILS REGARDING CONTRACTOR'S USE OF OWNER'S EXISTING TRAVELING BRIDGE HOIST/TROLLEY."

****

BIDDERS MUST ACKNOWLEDGE RECEIPT OF THIS ADDENDUM IN THE SPACE PROVIDED IN THE BID FORM

****

Dated at Columbus, Indiana
December 8, 2015

STRAND ASSOCIATES, INC.®
629 Washington Street
Columbus, IN 47201

STATE OF OHIO
HENRY W. McCAULEY JR.
E-73230
REGISTERED
PROFESSIONAL ENGINEER
12/8/15